Anvil CSI 3 Part MasterFormat Specifications

PIPES, VALVES AND FITTINGS FOR HVAC HEATING AND COOLING SYSTEMS SECTION 23 60 00

PART 13 GENERAL

- 13.1 SECTION INCLUDES
 - A. HVAC requirements.

13.2 RELATED SECTIONS

- A. Section 07 84 13 Penetration Firestopping Mortars.
- B. Section 08 31 16 Access Panels and Frames.
- C. Section 23 05 00 Common Work Results for HVAC.
- D. Section 23 05 29 Hangers and Supports for HVAC Piping and Equipment.
- E. Section 23 50 00 Central Heating Equipment.

13.3 REFERENCES

A. Manufacturers Standardization Society of the Valve and Fittings Industry (MSS) SP-127 Bracing for Piping Systems Seismic-Wind-Dynamic Design, Selection, Application.

13.4 SYSTEM DESCRIPTION

- A. Grooved products for steel and copper heating and cooling systems shall be used. Refer to Section 23 05 00 Common Work Results for HVAC.
 - 1. Galvanized fittings shall be used with galvanized pipe.
 - 2. Schedule 10 Type 304 or 316 grooved stainless steel pipe and grooved stainless steel fittings shall be used in conjunction with style 7091 DI-LOK fitting and copper tube sizes pipe systems up to 8 inch diameter.
 - 3. Couplings may be galvanized unless exterior pipe condition require the stainless steel corrosive resistant properties.
 - 4. Copper fittings shall be 99.9 percent lead free.
- B. Contractor Design Requirements:
 - 1. Incorporate in construction pipe hangers and supports to manufacturer's recommendations utilizing manufacturer's regular production components, parts and assemblies.

13.5 SUBMITTALS

- A. Submit under provisions of Section 01 30 00.
- B. [Product Data]: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Installation methods.
- C. Certifications:
 - 1. Product certificates signed by manufacturer certifying materials comply with specified performance characteristics and criteria and physical requirements. Certificates shall be furnished only as required by specific codes, upon request.
- D. Shop Drawings:
 - 1. Submit shop drawings and [Product Data] grouped to include complete submittals of related systems, products, and accessories in a single submittal.
- E. Closeout Submittals:
 - 1. Warranty: Warranty documents.
 - Operation and Maintenance Data: Operation and maintenance data for installed products in accordance with Division 1 Closeout Submittals (Maintenance Data and Operation Data) Section. Include methods for maintaining installed products, and precautions against cleaning materials and methods detrimental to finishes and performance.

13.6 QUALITY ASSURANCE

- A. Manufacturer Qualifications:
 - 1. Manufacturing facilities shall be registered to ISO 9001:2000 and assessed to ISO 9000.2000 standard. A copy of the current certificate shall be available upon request.
- B. Installer Qualifications:
 - 1. Contractor shall obtain all necessary permits and licenses pertaining to this Division (expense borne by the Contractor) and comply with Municipal and State Codes, Laws, Ordinances and Regulations, and the requirements of the National

Fire protection Association, and pay all fees and sales taxes as required, and post all bonds incident thereto.

C. Conduct pre-installation meeting to verify project requirements, coordinate with other trades, and establish conditions and completeness of substrate. Review manufacturer's installation instructions and manufacturer's warranty requirements.

13.7 DEFINITION

- A. "Piping" includes all pipe, fittings, valves, hangers, and other supports and accessories related to such piping.
- B. "Concealed" means hidden from sight in chases, furred spaces, shafts, hung ceilings, embedded in construction, in crawl spaces or buried.
- C. "Exposed" means not installed underground or "concealed" as defined above.
- D. "Fire Protection Work" is all of the work Indicated or required by the Contract Documents.
- E. "Or equivalent" means to possess the same performance qualities and characteristics and fulfill the utilitarian function without any decrease in quality, durability or longevity.
- F. "Provide" means the Contractor shall "furnish and install" work and/or equipment.
- G. "FPC" means the Fire Protection Contractor.

13.8 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Store and dispose of solvent-based materials, and materials used with solvent-based materials, in accordance with requirements of local authorities having jurisdiction.

13.9 PROJECT CONDITIONS

A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.

13.10 WARRANTY

- A. Contractor shall guarantee, in writing, that all work installed shall be free from any and all defects in workmanship and materials; that all apparatus shall develop capacities and characteristics specified; and that if, during the period of one year, or as otherwise specified, from the date of substantial completion, any defects in workmanship, material or performance appear, the Contractor shall, without cost to the Owner, remedy such defects within a reasonable time as specified in notice from the Owner's Representative. In default thereof, the Owner's Representative shall have the work done and charge the cost of the work to the Contractor.
- B. Furnish manufacturers written warranties for all equipment, stating effective date of Warranty, to the Owner's Representative.

PART 14 PRODUCTS

14.1 MANUFACTURERS

- A. Acceptable Manufacturer: Anvil International, which is located at: 2 Holland Way; Exeter, NH 03833; Tel: 603-418-2800; Email: bgunnell@anvilintl.com; Web: <u>www.anvilintl.com</u>
- B. Substitutions: Not permitted.
- C. Requests for substitutions will be considered in accordance with provisions of Section 01 60 00.

14.2 FITTINGS

A. Material:

- 1. Couplings and Grooved Flange Adapters shall conform to ASTM A-536 Ductile Grade 65-45-12
- 2. Coupling Track Head Bolts shall conform to ASTM A-183 Grade 2.
- 3. Hex nuts shall conform to ASTM A-563 Grade A. Bolts and nuts shall be zinc electroplated to ASTM B-633.
- 4. Fittings shall conform to Cast Ductile ASTM A-536.
- 5. Forged steel fittings shall conform to ASTM A-234 or A-105.
- 6. Segmental welded fittings shall conform to ASTM A-53.
- 7. Coatings shall be (Orange) rust inhibiting lead free coating.
- 8. Coating shall be hot dipped galvanized fittings shall conform to ASTM A-153.
- 9. Standard coupling gaskets for building services shall be Grade "EP" EPDM conforming to ASTM D-2000 with operating temperature range from -40 degrees F to +250 degrees F (-40 degrees C to 121 degrees C). or "E" EPDM conforming to ASTM D-2000 with operating temperature range from -40 degrees F to +230 degrees F (-40 degrees C to 110 degrees C). Or "E" type A Pre-Lubed EPDM for Fire Protection conforming to ASTM D-2000 with operating temperatures range from -40 degrees F to 150 degrees F (-40 degrees C).
- B. Gasket Lubricant: Coupling gaskets except where noted shall be lubricated with approved lubricant.
 - 1. Copper Systems: Gruvlok Xtreme Lubricant.
 - 2. Environments below -20 degrees F (-28 degrees C), and above 150 degrees F (66 degrees C) and systems subject to

continuous cycle temperature changes: Gruvlok Xtreme Lubricant.

- 3. Systems Subject to Thermal Cycling: Gruvlok Xtreme Lubricant.
- 4. "E" type A Pre-lubed Fire Protection Gaskets: No Lube required. Gruvlok Xtreme Lubricant required for dry pipe applications.
- C. Grooved Couplings for Steel Pipe Systems and other Approved Piping:
 - 1. Sizes 1 inch to 30 inches: Gruvlok Style 7401 Rigidlok couplings shall be used including style 7788 flange adapters fittings or 7012 Flange adaptor.
 - 2. Gruvlok Style 7402 SlideLOK ready to install coupling sizes 2 inch to 8 inch shall be used for rigid connections.
 - 3. Gruvlok Style 7001 (Flexible) couplings shall be used for vibration attenuation and noise suppression at equipment locations.
 - 4. Combination rigid, flexible, and outlet couplings shall be used for vibration, noise suppression and seismic tremor.
 - 5. Mechanical Clamp Tees style 7045, 7046 shall be used for branch outlets, cross configuration can be made with style 7047, 7048, & 7049.
 - 6. Standard coupling gaskets for building services shall be Grade "EP" EPDM conforming to ASTM D-2000 with operating temperature range from -40 degrees F to +250 degrees F (-40 degrees C to 121 degrees C). or "E" EPDM conforming to ASTM D-2000 with operating temperature range from -40 degrees F to +230 degrees F (-40 degrees C to 110 degrees C). Or "E" type A Pre-Lubed EPDM for Fire Protection conforming to ASTM D-2000 with operating temperatures range from -40 degrees C to 150 degrees F (-40 degrees C).
 - 7. Use other gasket materials as recommended for petroleum service and other applications, contact and Anvil Representaive for gasket compatibility questions.
 - 8. Flexible or other style couplings designed for axial motion or other movements shall be supported in strict accordance with industry standards.
- D. Grooved Couplings for Copper Tube Systems: Coupling working pressure not to exceed 300 psig (2.0 MPa).
 - 1. Gruvlok style 6400 Rigidlite and style 6084 coupling flange adapters fittings.
 - 2. Grade "EP" EPDM Flush Gap Gasket.
 - 3. Gruvlok Xtreme Lubricant.
- E. Grooved Flange Adapters:
 - 1. Style 7788 Flange adaptor fittings shall be used to transition from grooved to flange connection.
 - a. Sizes 2 inches through 12 inches are rated at 300 psig (2.0 MPa).
 - b. Conforms to ANSI class 125 or 150.
 - 1. Style 7012 & 7013 shall be used when space is at a premium .
 - a. Figures 7012 and 7013 flange adapters require sealing rings when used with certain flanged products.
 - b. Figure 7012: Conforms to ANSI class 125 or 150.
 - c. Sizes 2 inches through 20 inches are rated at 300 psig (2.0 MPa).
 - d. Size 24 inches is rated at 250 psig (1.72 MPa).
 - 4. Figure 7013: 2 inches through 12 inches available for ANSI class 250 or 300 lb bolt pattern and is rated at 750 psig (5 MPa).
- F. Grooved Fittings for Steel Piping Systems Shall be Gruvlok cast ductile, malleable, forged steel, and/or segmental welded steel fittings.
 - 1. Sizes 1 inches to 30 inches diameter:
 - a. Cast ductile conforms to ASTM A-536 or ASTM A-47.
 - b. Forged steel conforms to ASTM A-234.
 - c. Segmental welded conforms to ASTM A-53.
 - 2. Fittings shall be coated with an rust inhibiting lead free coating.
 - 3. Zinc electroplated fittings conform to ASTM B-633.
 - 4. Hot Dip Galvanized fittings conform to ASTM A-153.
 - 5. Standard Fittings shall be schedule 40 or standard wall. Other fittings are schedule 80 or light wall as dsigned.
- G. Grooved Copper Fittings: Gruvlok Wrot Copper fittings per ASTM B-75 and ANSI B-16.22, alloy C12200.
 - 1. Wrought Copper fittings size 2 inches to 8 type K, L, M, or DWV. Copper fittings shall be 99.9 percent lead free.
 - 2. Couplings and Wrought Copper Fittings shall be NSF-61, UPC Plumbing Code, & low lead approved.
- H. DI-LOK Gruvlok CTS Groove to IPS Groove Dielectric Fitting.
 - 1. Carbon steel conforming to ASTM A106, Nylon coated
 - 2. Operating Temperature -40 degrees F to +230 degrees F (-40 degrees C to 100 degrees C).
 - 3. Size range 2 inch to 6 inch.
 - 4. NSF-61, low lead approved.

- I. Di-Electric Insulated Pipe Connections: Di-LOK Figure 7088 or 7089 grooved by grooved or grooved by thread insulating nipples.
 - 1. Shall inhibit the formation of a galvanic cell between dissimilar metals.
 - 2. Housing: Steel tube to comply with ASTM A513; zinc plated.
 - 3. Liner: Polypropylene rated at 300 psig (2 MPa).
 - 4. Operating Temperature -40 degrees F to +230 degrees F (-40 degrees C to 100 degrees C).
 - 5. Size range is 1 inch to 6 inches diameter.
- J. Branch Outlets: Shall be Gruvlok Clamp-T Styles 7045 and 7046, and Clamp-T Cross Figure 7047, 7048 and 7049 with grooved or threaded outlets.
 - 1. Designated as a bolted-on positive pipe engagement branch outlet. Working pressure on schedule 40 pipe rated to 500 psi (3.5 KPa).
 - 2. Run Sizes 2 inches to 8 inches.
 - 3. Branch outlets from 1/2 inch to 3 inches diameter.
- K. Outlet Couplings: Shall be Gruvlok Figure 7042 with grooved or threaded outlets. Working pressure shall be 500-psig minimum.
 1. Run sizes 1-1/2 inches to 6 inches.
 - 2. Branch outlets from 1/2 inch to 2 inches diameter.
- L. Plain End Couplings and Fittings: Gruvlok Roughneck coupling Style 7005 and plain-end fittings to match.
 - 1. Size range is 2 inches to 16 inches diameter.
 - 2. Materials conform to ASTM A-536.
 - 3. Intended for working pressures 300 to 750 psig (2.0 KPa to 5.2 KPa) with bolts fully torque to factory recommend torque requirements on plain-end or beveled standard wall steel pipe and Gruvlok Plain-End fittings.
- M. Plain End "Sock-it" Method: Gruvlok Sock-it fitting series 7100 through 7107.
 - 1. Size range is 1 inch to 2-1/2 inches diameter.
 - 2. Material conforms to ASTM A-126 Class A Cast Iron.
 - 3. Working pressures from 175 300 psi (1.2 KPa to 2.0 KPa) UL/ULC listed and FM approved.
- N. Gaskets for Industrial and Other Piping Systems: Systems with different media products shall be provided with industrial grade gaskets as scheduled. Contact and Anvil Representative Gruvlok for application questions.
- O. Track Head Bolts and Hex Nuts: Couplings shall be furnished with heat-treated; oval neck track head bolts conforming to ASTM A-183 Grade 2. Bolts shall meet minimum tensile strength of 110,000 psi (758 KPa). Hex nuts shall be carbon steel conforming to ASTM A-563 Grade A. Bolts and nuts shall be zinc electroplated per ASTM B-633.

14.3 GROOVED CONNECTION FLOW CONTROL VALVES

- A. Grooved Butterfly Valve: Gruvlok Series 7700 and Series 8000GR grooved butterfly valves for On/Off service.
 - 1. Series 7700: Butterfly Valve Sizes 2 inches to 12 inches.
 - a. Listed in accordance with MSS SP-67.
 - b. Bubble tight at 300 psig (2.1 MPa).
 - c. Body Ductile Iron ASTM A-536 65-45-12 with nylon body coating.
 - d. Disc- Ductile Iron ASTM A-536 65-45-12.
 - 1. EPDM encapsulation Operating temperature -40 degrees F to 230 degrees F (-40 degrees C to 110 degrees C).
 - 2. Nitrile Disc encapsulation Operating temperature up to +180 degrees F (82 degrees C)
 - e. Trim 416 s/s. Rated for "Dead-end" service.
 - 2. Disc-to-stem attachment shall be made with splined stainless steel stems attached to disc by cold fusion process.
 - a. Disc/stem seals shall be triple redundant as follows: 1. Disc-to-valve body; 2. EPDM seat-to-stem; 3. EPDM O-rings in upper and lower shaft.
 - 3. Series 8000GR: Butterfly Valve
 - a. Size range 14 inches to 24 inches.
 - b. Bubble tight to 200-psig (1.4 MPa).
 - c. Body: Cast Iron to ASTM A-126 CL.B.
 - d. Disc- Nickel-Plated Ductile, Aluminum Bronze or Stainless Steel.
 - e. Liner- Standard EPDM or Nitrile. Operating temperature same as 7700 series.
 - f. Bearings: Upper and lower bearings Teflon reinforced.
 - g. Trim 316 and 416 s/s. Low Torque. Rated for "Dead-end" service.
 - 4. BFV Operators/Handles Series 7700 and 8000GR available in 2 position, 10 position latch lock, Infinite position with memory stop for sizes 2 inches through 8 inches, Double "D" with gear operators, chain wheel, and pneumatic or electric actuated for sizes 2 inches through 12 inches.
- B. Grooved Ball Valve Shall be Gruvlok Series 7500.
 - 1. Sizes 2 inches to 6 inches.

- 2. Standard port design rated for 740 psig (5.1 KPa) cwp.
- 3. Meets MSS SP-72 body and 100 percent hydro pressure tested. Bi-directional flow. Low torque operation.
- 4. Body and End Caps Ductile Iron ASTM 395
- 5. Ball and Stem chrome plated carbon steel 0r 316 Stainless Steel.
- 6. RPTFE and Nylon Seats and fluorocarbon stem and body seals.
- 7. Two position handle standard.
- A. Gruvlok Tri-Service Valves Model FTV-S.
- B. Gruvlok Tri-Service Valves Model FTV-A.
 - 1. Size: As indicated on drawings.
 - 2. Body and Yoke: Ductile iron; comply with ASTM A395 or ASTM A536.
 - 3. Disc: Cast iron, comply with ASTM A126.
 - 4. Stem: Bronze, comply with ASTM B21.
 - 5. Seat-Guide: Bronze, comply with ATM B584.
 - 6. Disc Guide: Cast iron, comply with ASTM A126.
 - 7. Seat: Bronze.
 - 8. Flanged Gland: Cast iron, comply with ASTM A126.
 - 9. Packing: Graphited, non-asbestos packing.
 - 10. Spring: 302 stainless steel.
 - 11. Stem Guide: Ductile iron; comply with ASTM A395 or ASTM A536.
- C. Gruvlok Balancing Valves Model GBV-S (Soldered).
- D. Gruvlok Balancing Valves Model GBV-T (Threaded).
 - 1. Size: As indicated on drawings.
 - 2. Material: Cast bronze.
 - 3. Type and Description: Y-style globe valve with 4 full-turn adjustment, pressure differential ports on both sides of the valve, with positive shutoff and micrometer type handwheel adjustment. Provide tamperproof memory stop.
- E. Gruvlok Balancing Valves Model GBV-G (Grooved-End Straight).
- F. Gruvlok Balancing Valves Model GBV-A (Grooved-End Angle).
 - 1. Size: As indicated on drawings.
 - 2. Body: Ductile iron, comply with ASTM A536.
 - 3. Disc: Bronze, comply with ASTM B584.
 - 4. Seat: Ultra-high strength engineered resin.
 - 5. Trim: Brass C-37700.
 - 6. O-ring: Nitrile.
- 14.4 MANUFACTURED UNITS
- A. Grooved (Non- Slam) Check Valve: Shall be Gruvlok Series 7800.
 - 1. Sizes 2 inches to- 12 inches. 300-psig (1.9 KPa).
 - 2. Body- Ductile. Exterior body coated with rust Inhibiting lead free coating.
 - 3. Clapper- sizes 2 inches to 12 inches Ductile Iron. Clapper facing- EPDM or Nitrile.
 - 4. Seat ring, spring, and hinge pin: Type 302 or 304 SS.
 - 5. Bronze hinge pin bushings.
 - 6. Iron hinge pin plugs and drain.
 - 7. A low service pressure of 1 psi (28 inch water head) (6895 Pa).
 - 8. Replaceable clapper.
 - 9. Horizontal or vertical service usage.
 - 10. MSS SP-71 & SP-80. 100 percent Shell Test & Hydro Seat test pressure 100 percent.
- B. Grooved (Globe Type) Silent Check Valve: Shall be Gruvlok Series 400 G.
 - 1. Sizes 2 inches to 10 inches.
 - 2. Rated for 200-psi(1.3 KPa) maximum working pressure.
 - 3. Operating temperature to 150 degrees F (65 degrees C).
 - 4. Body- Cast Iron A-48 Class 35
 - 5. Bronze Seat, Plug and Bushing.
 - 6. Gasket non Asbestos.
 - 7. Trim- Metal on Metal.
 - 8. Optional Trim- Bronze w/ Nitrile Seat, SS and SS w Nitrile seat.

- 9. Center-guided plug. (Positive noiseless opening and closing) Plug activated at 1/4 to 1/2 psi (1723 Pa to 3448 Pa).
- C. DI-LOK Gruvlok CTS Groove to IPS Groove Dielectric Fitting.
 - 1. Carbon steel conforming to ASTM A106, Nylon coated
 - 2. Operating Temperature -40 degrees F to +230 degrees F (-40 degrees C to 100 degrees C).
 - 3. Size range 2 inch to 6 inch.
 - 4. NSF-61, low lead approved.
- D. Di-Electric Insulated Pipe Connections: Di-LOK Figure 7088 or 7089 grooved by grooved or grooved by thread insulating nipples.
 - 1. Shall inhibit the formation of a galvanic cell between dissimilar metals.
 - 2. Housing: Steel tube to comply with ASTM A513; zinc plated.
 - 3. Liner: Polypropylene rated at 300 psig (2 MPa).
 - 4. Operating Temperature -40 degrees F to +230 degrees F (-40 degrees C to 100 degrees C).
 - 5. Size range is 1 inch to 6 inches diameter.
- E. Grooved Strainers: Shall be Gruvlok Series 7260-T ("Tee" Type) or 758-G ("Wye" Type) strainers.
 - 1. Tee Strainer Series 7260:
 - a. Sizes 2 inches to 18 inches.
 - b. Strainer in-line, twin-fold basket provides 100 percent of the projected pipe area for open flow.
 - c. Body- Ductible ASTM A-536 65-45-12, 2 inches to 12 inches
 - c. Body Carbon Steel Pipe ASTM A-53, Size 14 inches to 18 inch.
 - d. Basket- Stainless steel Type 304-basket standard #12 mesh (1/16 inch perf.)through 3 inches. Sizes 4 inches and larger standard with #6 mesh (1/8 inch perf.)
 - e. Horizontal or vertical service usage.
 - 2. Wye Strainers 758-G.
 - a. Size range 2 inches to 12 inches.
 - b. Body- Ductile iron. ASTM A-536, Ratee Working Pressure of 300 psig (1.9 KPa).
 - c. Baskets- Same as Tee Series.
- D. Grooved Suction Diffusers: Shall be Gruvlok Series 7250.
 - 1. Sizes 2-1/2 inches to 16 inches.
 - 2. Body- Ductile or Malleable Iron body for sizes 2-1/2 inches by 2-1/2 inches through 10 inches by 8 inches
 - 3. Body- Carbon steel to ASTM A-53 body for sizes 10 inches by 10 inches through 16
 - inches by 14 inches, rated working pressure, 300 psig (1.9 KPa).
 - 4. Strainer Basket- Stainless steel (3/16 inch perf.) With start-up #16 mesh pre-filter removable screen. Blow-down and gage plug standard.
- E. Flexible Connectors: Sizes 2 inches to 12 inches. Stainless steel tube and braid design. Carbon steel grooved, threaded & flanged end. Rated working pressure 150 to 300 psi (1.0 to 2.0 KPa).
- F. Triple Duty Combination Valves: Shall be Gruvlok "Tri-Service" (FTV-A/FTV-S) service valves.
 - 1. Sizes 2-1/2 inches to 12 inches.
 - 2. Services
 - a. Combination shut-off,
 - b. Non-slam silent check
 - c. Full throttling. Throttling flow indicator is standard.
 - 3. Horizontal or vertical service usage.
 - 4. Flow measurement ports on either side of valve body.
 - 5. Fixed or portable meters available for differential pressure measurement.
- G. Calibrated Circuit (Setter) Balancing Valves: Shall be GBV-Gruvlok "Circuit Balancing" Valve.
 - 1. Sizes 1/2 inch to 12 inches.
 - 2. Multi-turn adjustment.
 - 3. Positive shut-off.
 - 4. Tamper-proof memory stop.
 - 5. Pressure differential read-out ports.
 - 6. Differential Pressure Meter- Provide CBV differential pressure meter/transducer as required.

7. Direct Flow readout. Proportional balancing.

H. Automatic Air Vents - Gruvlok Models GAV-15 rated 150 psig and GAV-30 rated 300 psig.

14.5 PIPING

- A. Steel Piping:
 - 1. Refer to Section 23 05 00 Common Work Results for HVAC.
- B. Copper Piping:
 - 1. Refer to Section 23 05 00 Common Work Results for HVAC.
- C. Stainless Steel Piping:
 - 1. Refer to Section 23 05 00 Common Work Results for HVAC.
- D. Aluminum Piping:
 - 1. Refer to Section 23 05 00 Common Work Results for HVAC.
- E. Steel Piping:
 - 1. Refer to Section 23 05 00 Common Work Results for HVAC.
- F. Plastic Piping:
 - 1. Refer to Section 23 05 00 Common Work Results for HVAC.

14.6 ACCESS PANELS

- A. Provide access panels as required by Section 08 31 16 Access Panels and Frames.
- 14.7 FIRESTOPPING MATERIALS
 - A. Provide fire stopping assemblies as required by Section 07 84 13 Penetration Firestopping Mortars.

14.8 EQUIPMENT SUPPORTS

A. Fabricate equipment supports not provided by equipment manufacturer from structural grade steel meeting requirements of Section 05 12 16 - Fabricated Fireproofed Steel Columns.

14.9 EQUIPMENT ANCHOR BOLTS AND TEMPLATES

A. Provide templates to ensure accurate location of anchor bolts.

PART 15 EXECUTION

- 15.1 EXAMINATION
 - A. Do not begin installation until substrates have been properly prepared.
 - B. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

15.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.
- C. Provide openings as necessary to permit installation of piping or any other part of work under this Section.
- D. Provide sleeves for piping penetrating floor and masonry walls.
- E. This Contractor shall be responsible for establishing sizes and locations of all openings and lintels in new work and to transmit this information to the Contractor whose work is involved at such time as to avoid cutting and patching.
- F. All patching shall match adjacent surfaces.
- G. Contractor shall inspect and take note of existing conditions along with the Owner's Representative to avoid disputes regarding the condition of existing surface before work began.
- H. Openings through existing concrete shall be core-drilled or saw cut.

15.3 INSTALLATION

A. Install in accordance with manufacturer's instructions.

15.4 VALVE INSTALLATION

- A. Tri-Service Valves Models FTV-S, FTV-A:
 - 1. Mount valve to a spool piece on the discharge side of the pump. Spool piece required is based on a minimum recommended space of 12 inches for pump sizes 2 inches by 2 inches to 6 inches by 6 inches and 24 inches for pump sizes 8 inches by 8 inches to 12 inches by 12 inches.
 - 2. Do not mount valve directly to pump to avoid causing undesirable noise in the system.
 - 3. Leave sufficient clearance around valve for valve removal or repair.

- 4. Install valve in the direction of flow arrows on valve body.
- 5. Mount valve to flanged equipment using Gruvlok Flange Adapter or industry standard grooved coupling, suitable for system pressure and temperatures encountered.
- 6. Valve body has been designed to handle the weight of the pump on vertical in-line installations. The valve body is not designed to support the piping weight. Support piping by hangers. Provide pipe supports under valve and strainer bodies.
- B. Globe Valves Model GBV-S (Soldered), GBV-T (Threaded), Balancing Valves Model GBV-G (Grooved-End Straight), GBV-A (Grooved-End Angle):
 - 1. To ensure accuracy of measurement of GBV-S, GBV-T, GBV-G and GBV-A valves, locate valves at least 5 pipe diameters downstream from any fitting and at least 10 pipe diameters downstream from a pump.
 - 2. Install no fittings within 2 pipe diameters downstream of valve.
 - 3. Install valves with flow in the direction of the arrow on the valve body.
 - 4. Provide easy access to probe metering ports (PMPs), drain ports and hand wheel.
 - 5. For solder applications, solder valve body in line using 95/5 solder.
 - 6. Install valve-bonnet assembly into body, making sure non-asbestos gasket is in place.
 - 7. Install valves in horizontal or vertical piping as indicated.
 - 8. Do not install metering ports below the pipe (pointing down), as this will allow system sediment to accumulate in the ports.
 - 9. Metering ports and body/drain plugs may be interchanged for improved accessibility.

15.5 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Substantial Completion.

END OF SECTION