

GRUVLOK STAINLESS STEEL FITTINGS - TYPE 316

Gruvlok Schedule 10 Stainless Steel Fittings are segmentally welded with ends grooved to Gruvlok specifications. The standard material is 316 Stainless Steel unless otherwise noted with 304SS and/or Schedule 40 optional. Installation is quick and easy with the Gruvlok Figure 7400SS Coupling, or other Gruvlok product.

FIG. 7073SS

Stainless Steel Eccentric Reducers
Type 316




FIGURE 7073SS STAINLESS STEEL ECCENTRIC REDUCER					
Nominal Size	End to End*	Approx. Wt. Ea.	Nominal Size	End to End*	Approx. Wt. Ea.
<i>In./DN(mm)</i>	<i>In./mm</i>	<i>Lbs./Kg</i>	<i>In./DN(mm)</i>	<i>In./mm</i>	<i>Lbs./Kg</i>
1½ x 1 40 x 25	8½ 216	1.7 0.8	3 x 1½ 80 x 40	9½ 241	4.5 0.9
1½ x 1¼ 40 x 32	8½ 216	4.5 2.0	4 x 2 100 x 50	10 254	6.7 3.0
2 x 1 50 x 25	9 229	2.2 1.0	4 x 2½ 100 x 65	10 254	7.3 3.3
2 x 1¼ 50 x 32	9 229	2.4 1.1	4 x 3 100 x 80	10 254	7.9 3.6
2 x 1½ 50 x 40	9 229	2.5 1.1	6 x 2½ 150 x 65	11½ 292	12.8 5.8
2½ x 1 65 x 25	9½ 241	3.2 1.5	6 x 3 150 x 80	11½ 292	13.6 6.2
2½ x 1½ 65 x 40	9½ 241	3.6 1.6	6 x 4 150 x 100	11½ 292	14.9 6.8
2½ x 2 65 x 50	9½ 241	4.0 1.8	8 x 4 200 x 100	12 305	19.7 8.9
3 x 1 80 x 25	9½ 241	4.0 1.8	8 x 6 200 x 150	12 305	23.2 10.5
3 x 1¼ 80 x 32	9½ 241	4.3 2.0			

Notes:

- *Dimensions may differ from those shown above. Contact an Anvil Representative for more information.
- Fabricated fittings weights are based on Schedule 10 pipe.
- Fabricated Schedule 10, 316SS and Schedule 40 Center to End dimensions are the same.
- The pressure rating for the Gruvlok Schedule 10 Stainless Steel Fittings are equal to the pressure rating of the coupling used on Schedule 10 pipe as shown in the Working Pressure Ratings Chart for Stainless Steel Roll Grooved Pipe on page 169.
- The pressure rating for the reducing tees, concentric reducers and eccentric reducers should be based upon the dimension of the weakest end.

Center to End dimensions differ from the 304 A Series, when ordering verify if 304 dimensions are required.



Certified to
ANSI/NSF 61

PROJECT INFORMATION		APPROVAL STAMP	
Project:		<input type="checkbox"/> Approved	
Address:		<input type="checkbox"/> Approved as noted	
Contractor:		<input type="checkbox"/> Not approved	
Engineer:		Remarks:	
Submittal Date:			
Notes 1:			
Notes 2:			