



For Listings/Approval Details and Limitations, visit our website at www.anvilintl.com or contact an Anvil® Sales Representative.

E-3 22¹/₂° ELBOW				
Nominal Size	O.D.	Max. Working Pressure	Center to End	Approx. Wt. Ea.
<i>In./DN(mm)</i>	<i>In./mm</i>	<i>PSI/bar</i>	<i>In./mm</i>	<i>Lbs./Kg</i>
1	1.315	300	1 ⁵ / ₈	0.5
25	33.4	20.7	41	0.2
1 ¹ / ₄	1.660	300	1 ³ / ₄	0.8
32	42.2	20.7	44	0.4
1 ¹ / ₂	1.900	300	1 ³ / ₄	0.7
40	48.3	20.7	44	0.3
2	2.375	300	2	1.6
50	60.3	20.7	51	0.7
2 ¹ / ₂	2.875	300	2	2.1
65	73.0	20.7	51	1.0
3	3.500	300	2 ¹ / ₄	3.1
80	88.9	20.7	57	1.4
4	4.500	300	2 ¹ / ₈	5.4
100	114.3	20.7	73	2.4
5	5.563	300	2 ¹ / ₈	7.8
125	141.3	20.7	73	3.5
6	6.625	300	3 ¹ / ₈	8.3
150	168.3	20.7	79	3.8
8	8.625	300	3 ¹ / ₈	17.9
200	219.1	20.7	98	8.1
10	10.750	300	4 ³ / ₄	30.0
250	273.1	20.7	121	13.6
12	12.750	300	4 ⁷ / ₈	40.4
300	323.9	20.7	124	18.3

MATERIAL SPECIFICATIONS

FABRICATED FITTINGS:

- 1"-10" Carbon Steel, Schedule 40, conforming to ASTM A-53, Grade B
- 12" Carbon Steel, Standard Wall, conforming to ASTM A-53, Grade B

COATINGS:

- Rust inhibiting paint Color: ORANGE (standard) or
- Hot Dipped Zinc Galvanized conforming to ASTM A-153 (optional)
- Other available options: Example: RAL3000 or RAL9000 Series

PROJECT INFORMATION		APPROVAL STAMP
Project:		<input type="checkbox"/> Approved
Address:		<input type="checkbox"/> Approved as noted
Contractor:		<input type="checkbox"/> Not approved
Engineer:		Remarks:
Submittal Date:		
Notes 1:		
Notes 2:		