



For Listings/Approval Details and Limitations, visit our website at www.anvilint.com or contact an Anvil® Sales Representative.

E-4 11¹/₂° ELBOW				
Nominal Size	O.D.	Max. Working Pressure	Center to End	Approx. Wt. Ea.
<i>In./DN(mm)</i>	<i>In./mm</i>	<i>PSI/bar</i>	<i>In./mm</i>	<i>Lbs./Kg</i>
1	1.315	300	1 ³ / ₈	0.3
25	33.4	20.7	35	0.1
1 ¹ / ₄	1.660	300	1 ³ / ₈	0.5
32	42.2	20.7	35	0.2
1 ¹ / ₂	1.900	300	1 ³ / ₈	0.7
40	48.3	20.7	35	0.3
2	2.375	300	1 ³ / ₈	0.9
50	60.3	20.7	35	0.4
2 ¹ / ₂	2.875	300	1 ¹ / ₂	1.5
65	73.0	20.7	38	0.7
3	3.500	300	1 ¹ / ₂	2.0
80	88.9	20.7	38	0.9
4	4.500	300	1 ³ / ₄	3.3
100	114.3	20.7	44	1.5
5	5.563	300	2	5.0
125	141.3	20.7	51	2.3
6	6.625	300	2	6.5
150	168.3	20.7	51	2.9
8	8.625	300	2	10.0
200	219.1	20.7	51	4.5
10	10.750	300	2 ¹ / ₈	14.5
250	273.1	20.7	54	6.6
12	12.750	300	2 ¹ / ₄	29.3
300	323.9	20.7	57	13.3

MATERIAL SPECIFICATIONS

FABRICATED FITTINGS:

- 1"-10" Carbon Steel, Schedule 40, conforming to ASTM A-53, Grade B
- 12" Carbon Steel, Standard Wall, conforming to ASTM A-53, Grade B

COATINGS:

- Rust inhibiting paint Color: ORANGE (standard) or
- Hot Dipped Zinc Galvanized conforming to ASTM A-153 (optional)
- Other available options: Example: RAL3000 or RAL9000 Series

PROJECT INFORMATION		APPROVAL STAMP	
Project:		<input type="checkbox"/> Approved	
Address:		<input type="checkbox"/> Approved as noted	
Contractor:		<input type="checkbox"/> Not approved	
Engineer:		Remarks:	
Submittal Date:			
Notes 1:			
Notes 2:			