



For Listings/Approval Details and Limitations, visit our website at [www.anvilint.com](http://www.anvilint.com) or contact an Anvil® Sales Representative.

<b>X-1 CROSS</b>			
Nominal Size	O.D.	Center to End	Approx. Wt. Ea.
In./DN(mm)	In./mm	In./mm	Lbs./Kg
1	1.315	2¼	1.3
25	33.4	57	0.6
1¼	1.660	3¾	2.0
32	42.2	95	0.9
1½	1.900	3¾	2.2
40	48.3	95	1.0
2	2.375	3¾	2.2
50	60.3	95	1.0
2½	2.875	3¾	3.3
65	73.0	95	1.5
3	3.500	3¾	5.0
80	88.9	95	3.2
4	4.500	5	6.6
100	114.3	127	3.0
5	5.563	5¼	9.3
125	141.3	133	4.2
6	6.625	6½	14.5
150	168.3	165	6.6
8	8.625	7¾	28.5
200	219.1	197	12.9
10	10.750	9	40.5
250	273.1	229	18.4
12	12.750	10	57.0
300	323.9	254	25.9

## MATERIAL SPECIFICATIONS

### FABRICATED FITTINGS:

**1" - 10"** Carbon Steel, Schedule 40, conforming to ASTM A-53, Grade B

**12"** Carbon Steel, Standard Wall, conforming to ASTM A-53, Grade B

### COATINGS:

- Rust inhibiting paint Color: ORANGE (standard) or
- Hot Dipped Zinc Galvanized conforming to ASTM A-153 (optional)
- Other available options: Example: RAL3000 or RAL9000 Series

## PROJECT INFORMATION

## APPROVAL STAMP

<b>Project:</b>	<input type="checkbox"/> Approved
<b>Address:</b>	<input type="checkbox"/> Approved as noted
<b>Contractor:</b>	<input type="checkbox"/> Not approved
<b>Engineer:</b>	<b>Remarks:</b>
<b>Submittal Date:</b>	
<b>Notes 1:</b>	
<b>Notes 2:</b>	